

Methodologies Applied for Modeling and Analysis of Impulsive Grounding Systems – A Study Review

Daniel S. Gazzana¹, Arturo S. Bretas¹, Guilherme A. D. Dias¹ and Marcos Telló²

¹ Department of Electrical Engineering
UFRGS, Federal University of Rio Grande do Sul
Av. Osvaldo Aranha, 103, CEP: 90035-190, Porto Alegre, RS (Brazil)
phone: +55 51 3308-4291, fax: +55 51 3308-3129, e-mail: dgazzana@ece.ufrgs.br,
abretas@ece.ufrgs.br, gaddias@terra.com.br

² Department of Electrical Engineering
PUCRS, Pontifical Catholic University of Rio Grande do Sul
Av. Ipiranga, 6681 - Prédio 30, CEP: 90619-900, Porto Alegre, RS (Brazil)
phone: +55 51 3320-3594, fax: +55 51 3320.3540, e-mail: tello@ee.pucrs.br

Abstract

Grounding systems are one of the main resources capable of keeping the physical integrity of an installation in the event of a lightning discharge. Grounding schemes are also an important system for population security [1]-[2].

The human tolerable step and touch potentials usually are considered as reference parameters only on the steady-state/low frequency ground mesh analysis, however such potentials can be exceeded in the transitory period of an electric impulse as lightning surges. In this way, impulsive analysis during the transitory period must be evaluated [3].

In the occurrence of a lightning surge, grounding systems are responsible for electric current conduction to the ground. In this phenomenon, the grounding mesh impedance must be less than the equivalent impedance of the remaining electrical system, elsewhere, the electric discharge will flow to the system causing severe physical and material damages.

Models development for suitable grounding systems can provide the necessary knowledge for the construction of more efficient ground meshes. More efficient grounding meshes allow a security and quality increase of the electrical power system operation [4].

The impulsive and high frequency analysis of grounding systems traditionally is made by the solution of the Maxwell equations. Such methodology, already known and consolidated is based on the solution of a set of differential equations that represent the grounding, earth and electrode. However, grounding systems physical characteristics modeling with consequent mathematical solution of differential equations is not a trivial task [5]-[6].

In recent years, other numerical and analytical methodologies had been developed and adjusted for grounding systems analysis. The Finite Element Method (FEM) [7], the Moments Method (MoM) [8]-[9], the Transmission Line Approach methods integrated in transient analysis programs [10], and the Transmission Line Modeling Methods (TLM) [11],[12],[13] are some of the most important ones. The TLM is between the most studied and developed in these recent years, being able to be used for Maxwell equations resolution for electromagnetic waves propagation. Complex geometries, non-homogeneous medium with losses, materials with changeable parameters can be modeled with the TLM.

In this context, the goal of this paper is to present a study review of the main applicable methodologies used for impulsive analysis of grounding systems, emphasizing its characteristics, advantages and disadvantages.

Key words:

Impulsive grounding systems, transient analysis, numerical and analytical techniques, lighting.

Acknowledgement

The authors wish to thank Federal University of Rio Grande do Sul (UFRGS) by the facilities offered and to Ministry of the Education of Brazil (CAPES) by the financial assistance.

References

- [1] C. Portela, "(Grounding Systems Behavior for Atmospheric Discharges - Determination of Relative Effect related to People and Equipments Security and the

- Interference in the Protection and Control Systems)," XIV SNPTEE, Belem-PA, Brazil, 1997.
- [2] W. Jaroslaw, "Distribution of Step and Touch Voltages at Typical HV/MV Substation During Lightning," XIII International Conference on Electromagnetics Disturbances, EMD 2003, Bialystok, Poland, 24-26 September 2003.
- [3] M. A. Mattos, "(Transients in Grounding Meshes)," XVII SNPTEE, GES-16, Uberlândia-MG, Brazil, October 2003.
- [4] Marcos Telló, Guilherme A. D. Dias, Adroaldo Raizer, Hugo D. Almager, Thair I. Mustafá, Vilson L. Coelho, (Grounding Systems in Low Frequency, High Frequencies and impulsive with Case Studies) EDIPUCRS, 2007.
- [5] K. Q. da Costa, V. Dmitriev, "Software Based on Mom Model to Analyze Elettromagnetic Transients in Grounding Systems," International Conference on Grounding and Earthing (GROUND 2006) & 2nd International Conference on Lightning Physics and Effects, Maceió, Brazil, November, 2006.
- [6] C. Portela, "Frequency and Transient Behavior of Grounding Systems. I Physical and Methodological Aspects. II Practical Application Examples," Proceedings IEEE International Symposium on Electromagnetic Compatibility, p. 379-390, 1997.
- [7] Yaqing Liu, Transient Response of Grounding Systems Caused by Lightning: Modelling and Experiments, Comprehensive Summaries of Uppsala Dissertations from the Faculty of Science and Technology 1015, 2004.
- [8] F. Dawalibi, A. Selbi, "Electromagnetic Fields of Energized Conductors," IEEE PES 1992 Summer Meeting Paper 92 SM 456-4 PWRD, 1992.
- [9] S. Fortin, Y. Yang, J. Ma, and F. P. Dawalibi, "Electromagnetic Fields of Energized Conductors in Multilayer Soils", CEEM'2006/Dalian, 2006.
- [10] F. E. Menter, L. Grcev, "EMTP-Based Model for Grounding System Analysis", IEEE Transactions on Power Delivery, Vol. 9, No. 4, October 1994.
- [11] P. B. Johns, R. L. Beurle, "Numerical Solution of 2-Dimensional Scattering Problems Using a Transmission-Line Matrix," Proc. IEEE, v. 118, n. 9, p.1203 – 1208, September 1971.
- [12] C Christopoulos, The Transmission-Line Modeling Method – TLM. 1. ed. New York: IEEE PRESS, 1995.
- [13] C Christopoulos, The Transmission-Line Modeling Method in Electromagnetics. Morgan & Claypool Publishers, August 2006.